

Schena, Cristeen

From: Aram Varjabedian <avarjabedian@woodardcurran.com>
Sent: Tuesday, May 08, 2018 10:51 PM
To: tberardinelli@town.hull.ma.us; Bill Boornazian; david.burns (david.burns@state.ma.us); Jim Dow; Frank Cavaleri; jstruzziery@town.hull.ma.us; jsullivan (jsullivan@town.hull.ma.us); kbornheim (kbornheim@town.hull.ma.us); Krahforst, Chris (ckrahforst@town.hull.ma.us); Lemnios, Philip (plemnios@town.hull.ma.us); coconnor@town.hull.ma.us; Robert Scott; Turin, David; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us)
Subject: RE: DEP Notification - Final reporting - Hull, MA - MA0101231 - 24 E Street
Attachments: SSO_Notification_report_50818_for_050318_24_E_Street_optimized.pdf

Good evening:

Please find the completed SSO Bypass Notification Form for the incident that occurred at 24 E Street, Hull, MA on 5/3/18.

Should you have any questions or need additional information, please let me know.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS

From: Aram Varjabedian
Sent: Friday, May 04, 2018 1:06 PM
To: Aram Varjabedian <avarjabedian@woodardcurran.com>; Berardinelli, Terri <tberardinelli@town.hull.ma.us>; Bill Boornazian <wboornazian@woodardcurran.com>; david.burns (david.burns@state.ma.us) <david.burns@state.ma.us>; Dow, James (jdow@town.hull.ma.us) <jdow@town.hull.ma.us>; Frank Cavaleri <fcavaleri@woodardcurran.com>; jstruzziery (jstruzziery@town.hull.ma.us) <jstruzziery@town.hull.ma.us>; jsullivan (jsullivan@town.hull.ma.us) <jsullivan@town.hull.ma.us>; kbornheim (kbornheim@town.hull.ma.us) <kbornheim@town.hull.ma.us>; Krahforst, Chris (ckrahforst@town.hull.ma.us) <ckrahforst@town.hull.ma.us>; Lemnios, Philip (plemnios@town.hull.ma.us) <plemnios@town.hull.ma.us>; O'Connor, Carol <coconnor@town.hull.ma.us>; Robert Scott (rscott@woodardcurran.com) <rscott@woodardcurran.com>; Turin, David (Turin.David@epa.gov) <Turin.David@epa.gov>; Joyce, Ryan (FWE) (ryan.joyce@state.ma.us) <ryan.joyce@state.ma.us>
Subject: DEP Notification - Initial reporting - Hull, MA - MA0101231 - 24 E Street

Good afternoon:

This email is to notify & report that a sewer blockage in the 8-inch gravity sewer line near Pump Station 6 occurred yesterday 5/4/18. A call came into the Sewer Department at approximately 8:35am from the resident at 24 E Street, indicating that they had experienced a back-up into the downstairs shower.

Staff were dispatched to the area to investigate and found the Alphabet Street Area Bayside sewer lines were surcharged, and no flow was reaching the pump station. Calls were made for additional support: Rosano-Davis Pumping for pump truck support and Truax Corporation for vactor/jet truck support. A portable trash pump was also set up on "L" Street with discharge to Nantasket Ave [interceptor].

There was no release of sewage, however, the clearing of the sewer line that is located under the playground took a number of hours, since the surcharged sewage in the system needed to be lowered initially. The line blockage was cleared at approximately 5:00pm.

The attached map shows the location of the blockage and the reported back-up. Further investigation is necessary for sewer line that was blocked.

A completed SSO/Bypass Notification Form will be completed and forwarded. Should you have any questions or concerns, please let me know.

Sincerely,

Aram

Aram Varjabedian
Plant Manager
Hull Wastewater Treatment Facility
1111 Nantasket Avenue | Hull, MA 02045
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334
www.woodardcurran.com



COMMITMENT & INTEGRITY DRIVE RESULTS